

**ITEM 6.1:**     **MPP Stage 2 – 1495 Blue Oaks Boulevard – NIPA PCL CO-31 and CO-41 – Campus Oaks Town Center QSR1 and PAD1 – PL20-0031**

**REQUEST**

The applicant requests approval of a Major Project Permit (MPP) Stage 2 to evaluate the architecture and design of two buildings in the Campus Oaks Town Center development. Quick-Serve Restaurant 1 (QSR1) is a proposed 2,418 square-foot restaurant with a drive-through. Pad Building 1 (PAD1) is a proposed 7,200 square-foot multi-tenant building consisting of a credit union and convenience restaurant.

Applicant – Karendia McDonald, Borges Architectural Group  
Owner – Kevin Parker, Armstrong CO Roseville, LLC

**SUMMARY RECOMMENDATION**

The Planning Division recommends that the Planning Commission take the following actions:

- A. Adopt the two (2) findings of fact and approve the Major Project Permit Stage 2 subject to seventy-five (75) conditions of approval.

**SUMMARY OF OUTSTANDING ISSUES**


There are no outstanding issues associated with this request. The applicant has reviewed and is in agreement with the recommended conditions of approval.

**BACKGROUND**

The project site is located at 1495 Blue Oaks Boulevard at the southeastern corner of Blue Oaks Boulevard and Woodcreek Oaks Boulevard, within the City's North Industrial Plan Area. The site is part of the Hewlett Packard Campus Oaks (HPCO) Master Plan area. The HPCO Master Plan redesignated 198 acres of industrial land formerly owned by Hewlett Packard to a mix of Low, Medium, and High Density Residential; Business Professional, Community Commercial, Tech/Business Park – Light Industrial, Parks and Recreation, Open Space, and Public/Quasi-Public. The HPCO Master Plan also established development standards, permitted uses, and a development plan for the area, and a tentative subdivision map to create large lots based on the land use plan. The project received final approval in August of 2015.

The two subject buildings are part of the Campus Oaks Town Center development. Campus Oaks Town Center (COTC) is the commercial shopping center portion of the HPCO Master Plan. The entire HPCO Master Plan project was approved through the Major Project Permit (MPP) process. Therefore, any modifications to the site plan require an MPP Stage 1 modification and any new building elevations require an MPP Stage 2 approval. The building footprints for the COTC were approved by the Planning Commission on October 25, 2018 (file #PL18-0080) (Figure 1). Building elevations were also approved for 9 of the 15 buildings in the center. The proposed project includes an MPP Stage 2 to approve the elevations for buildings QSR1 and PAD1 within the center.

Figure 1 – Approved COTC Site Plan



## SITE INFORMATION

**Location:** 1495 Blue Oaks Blvd.

**Total Size:** 29.64 acres

**Topography and Setting:** The site topography is generally flat, due to the mass grading activities which have occurred on the project site. The site is bounded to the north by Blue Oaks Boulevard, to the west by Woodcreek Oaks Boulevard, to the east by undeveloped land, and to the south by Painted Desert Way. Roseville Parkway extends through the eastern third of the project area.

## EVALUATION

The proposed project is being evaluated through the Major Project Permit (MPP) entitlement process. The intent of the MPP process is to streamline the review of large and diverse projects that could be constructed over a period of several years. The MPP process allows for the resolution of site issues prior to the review of more detailed architectural and landscape issues that may not be finalized at the time the site plan is ready. In accordance with the City's MPP Ordinance, the MPP review process is

segregated into three separate stages. The evaluation section of this report includes an analysis of the requested MPP Stage 2. The findings for a Major Project Permit Stage 2 are as follows:

- 1. The Architecture and Landscaping is consistent with the General Plan, applicable Specific Plan, and adopted City design guidelines; and Phase 1 approval; and**
- 2. The design and installation of the Preliminary Development Plan shall not be detrimental to the public health and safety, or be materially detrimental to the public welfare.**

The entitlement is analyzed for its consistency with the goals and policies of the applicable regulations. The HPCO Design Guidelines and the HPCO Master Plan provide standards and guidelines for streetscapes and project design intent, but defer to the City's Community Design Guidelines (CDG) for the evaluation of architecture and building design. Key guidelines within the CDG applicable to this project include direction to:

- define development character through the use of consistent design concepts (CC-39);
- use varied wall planes, rooflines, and building form (CC-41);
- provide articulation at main building entries (CC-44);
- provide variation in colors and materials (CC-46); and
- provide architectural treatment for all sides of a building facing public areas (CC-47);

## **MPP Stage 2**

Stage 2 of the MPP process includes the review of the architectural design of buildings PAD1 and QSR1. The project has been evaluated based on the applicable design standards. The two proposed buildings share many of the same design elements and so will be evaluated together. The proposed buildings are one story in height, and are designed to be architecturally consistent with the previously approved buildings in the Campus Oaks Town Center (File #PL18-0080) (Figure 2). The landscape areas around each of the buildings were reviewed as part of the previous approval and are not proposed for modification by this application. The details of the building architecture are further evaluated below.

**Architecture:** The proposed building elevations are consistent with the modern agrarian design concept developed for the COTC as a whole. The modern agrarian style incorporates traditional building forms and materials associated with rural or agricultural settings—such as barn-style building forms and wood or metal cladding or roofs—coupled with modern design styles such as flat parapets, stucco, and modern glass and metal storefronts. Because many of the elevations of buildings in the COTC are already approved, the QSR1 and PAD1 buildings will be evaluated based on their consistency with the approved designs, colors, and materials.

Building PAD1 incorporates many of the materials used throughout the project including integrated red color metal panels on the northwest corner of the building facing the public way (Figure 3). The red panels bring emphasis to the building and provides an attractive view of the center from Blue Oaks Blvd. and Woodcreek Oaks Blvd. Similarly, faux-wood tile is used around the doors on the north side of the building as well as over entrances on the south side of the building, which provides a variation of color and material to add visual interest. Articulation is provided at building entries with protruding storefronts that differ in color and materials from the adjacent recessed portions of the building. A patio area with posts and roofing as well as awnings throughout add further variety to the materials and articulation.

**Figure 2 – Previously Approved PAD 2 Elevations**



**Figure 3 – PAD 1 Proposed Elevations**



Building QSR1 also incorporates the colors and materials of the rest of the COTC (Figure 4). The future tenant of QSR1, a Del Taco restaurant, has certain national brand identification requirements. Despite these requirements, including a flat roof, light green accents, and metal artwork, the majority of the materials are consistent with the rest of the COTC. The consistent materials include red soffit panels, faux-wood tile, and gray stucco.

**Figure 4 – QSR1 Proposed Elevations**



## **CONCLUSION**

The proposed project is consistent with the City of Roseville General Plan, NIPA, Zoning Ordinance, CDG, and the prior Campus Oaks Town Center project approvals. Therefore, staff recommends that the Planning Commission approve the proposed MPP Stage 2 for buildings QSR1 and PAD1 in the Campus Oaks Town Center.

## **PUBLIC OUTREACH**

The proposed project was distributed to the various agencies and departments which have requested notice of City applications, and all comments were considered and incorporated into the Conditions of Approval, as appropriate. Notice of the application was also distributed to the Roseville Coalition of Neighborhood Associations. No comments were received. A public notice of the Planning Commission hearing was published on April 9, 2020, and was distributed to all property owners within 300 feet of the project site. To date, no comments have been received.

## **ENVIRONMENTAL DETERMINATION**

An Addendum to the Hewlett Packard Master Plan EIR (SCH #95112022) was prepared for file #PL18-0080 consistent with California Environmental Quality Act Section 15164. This Addendum evaluated the impact of development of the Campus Oaks Town Center, including buildings QSR1 and PAD1. The proposed project is substantially consistent with the previously evaluated project, and no new effects are expected to occur.

## **RECOMMENDATION**

The Planning Division recommends the Planning Commission take the following actions:

- A. Adopt the two (2) findings of fact as stated above and approve the **MAJOR PROJECT PERMIT STAGE 2 – NIPA PCL CO-31 and CO-41 – Campus Oaks Town Center QSR1 and PAD1 – 1495 Blue Oaks Boulevard – FILE # PL20-0031** subject to seventy-five (75) conditions of approval.

### **CONDITIONS OF APPROVAL FOR MPP STAGE 2 (FILE # PL20-0031)**

1. This Major Project Permit approval shall be effectuated within a period of two (2) years from April 23, 2020 and if not effectuated shall expire on April 23, 2022. Prior to said expiration date, the applicant may apply for an extension of time, provided this approval does not extend the expiration beyond April 23, 2023. (Planning)
2. The project is approved as shown in Exhibit A and as conditioned or modified below. (Planning)
3. The project shall comply with all applicable required environmental mitigation identified in the Hewlett-Packard Master Plan Environmental Impact Report and subsequent Hewlett-Packard Campus Oaks Addendums, and shall include all applicable mitigation measures as notes on the grading plans. (All Departments) (Planning)
4. The project shall be addressed as 1495 Blue Oaks Bl. The addresses for the buildings identified in the plans are correct per PL18-0080. Please ensure these addresses are used going forward. All projects with multi-tenants or buildings must submit a site plan with building footprint(s) to the Development Services Department (Business Services – Addressing) for building/suite addressing. (Business Services)
5. The applicant shall pay City's actual costs for providing plan check, mapping, GIS, and inspection services. This may be a combination of staff costs and direct billing for contract professional services. Project billing may occur up to two (2) months after the end of warranty or the Notice of Termination date for the SWPPP, whichever occurs later. (Engineering, Environmental Utilities, Electric, Finance)
6. The design and construction of all improvements shall conform to the Design and Construction Standards of the City of Roseville, or as modified by these conditions of approval, or as directed by the City Engineer. (Engineering)
7. The applicant shall not commence with any on-site improvements or improvements within the right-of-way until such time as grading and/or improvement plans have been submitted for review and are approved with grading and/or encroachment permits issued by the Department of Development Services – Engineering Division (Engineering)
8. The approval of this project does not constitute approval of proposed improvements as to size, design, materials, or location, unless specifically addressed in these conditions of approval. The developer shall

submit civil drawings to the Department of Development Services – Engineering Division for review and approval. (Engineering)

### **PRIOR TO ISSUANCE OF BUILDING PERMITS**

9. Parking lot design shall conform to the City's design standards, including the following minimum standards for parking stalls:
  - a) All parking stalls shall be double-striped. Parking stalls adjacent to sidewalks, landscaped areas or light fixtures, and all Accessible stalls shall have a 6-inch raised curb or concrete bumper. (Planning)
  - b) Standard – 9 feet x 18 feet; Compact – 9 feet x 16 feet; Accessible – 14 feet x 18 feet (a 9-foot-wide parking area plus a 5-foot-wide loading area) and a minimum of one (1) parking space shall be Accessible van accessible – 17 feet x 18 feet (9-foot-wide parking area plus an 8-foot-wide loading area). (Planning)
  - c) An 'exterior routes of travel' site accessibility plan incorporating slope, cross-slope, width, pedestrian ramps, curb ramps, handrails, signage, detectable warnings or speed limit signs or equivalent means shall comprise part of the site improvement plans submitted to City for review, prior to building plan check approvals. This site accessibility plan shall also include:
    - i) Accessible parking stalls shall be dispersed and located closest to accessible entrances. The total number of accessible parking spaces shall be established by Table 11B-208.2 of the CBC.
    - ii) Accessible Parking spaces and crosswalks shall be signed, marked and maintained as required by Chapter 11 of the CBC.
    - iii) Accessible parking and exterior route of travel shall comply with CBC, Sections 11B-206 and 11B-208. (Building)
10. Signs and/or striping shall be provided on-site as required by the Development Services Department – Planning Division to control on-site traffic movements. Parking lot striping and signage shall be maintained in a visible and legible manner. (Planning)
11. The plans submitted to the Building Divisions for permits shall indicate all approved revisions/alterations as approved by the Commission, including all conditions of approval. (Planning)
12. The project Landscape Plans shall comply with the following:
  - a) The Landscape Plan shall indicate the location of, and be designed to avoid conflicts with, all pole-mounted light fixtures and utility equipment including (but not limited to) electric transformers; switchgear; and overhead lines; backflow preventer; fire department connections; and public water, sewer, and storm drain facilities. (Planning, Fire, Environmental Utilities, Electric, Engineering)
  - b) The tree plantings in the parking lot shall be designed to provide a minimum of 50% shade coverage after 15 years. (Planning)
  - c) At a minimum, landscaped areas not covered with live material shall be covered with a rock, (3") bark (no shredded bark) or (3") mulch covering. (Planning)

- d) The landscape plan shall comply with the Landscape Guidelines for HP Campus Oaks Master Plan and the City of Roseville Water Efficient Landscape Ordinance. (Planning, Environmental Utilities)
  - e) Landscaping adjacent to preserve areas shall consist of California native, drought-tolerant groundcover, shrubs, plants, and trees. (Open Space, Planning)
  - f) All landscaping in areas containing electrical service equipment shall conform to the Electrical Department's Landscape Requirements and Work Clearances as outlined in Section 10.00 of the Department's "Specification for Commercial Construction". (Electric)
  - g) Slopes within landscape planter shall be no more than 3:1. A two-foot flat bench located at back-of-walk shall be included in the landscape area to slow or allow absorption of nuisance run-off from the planters. (Parks, Recreation, and Libraries)
  - h) All landscaping shall conform to the standards of crime prevention through environmental design with the intent to create natural surveillance, controlling access, and territorial reinforcement to property boundaries. (Police)
13. Any roof-mounted equipment and satellite dishes proposed shall be shown on the building plans. The equipment shall be fully screened from public streets and the surrounding properties. (Planning)
14. At the time of building permit application and plan submittal, the project applicant shall submit a proposed plan which shows the proposed suite addressing for individual tenant spaces within the building. The Building Official, or the designee, shall approve said plan prior to building permit approval. Refer to the City of Roseville Addressing Guidelines. (Building)
15. A separate Architectural Site Accessibility Plan which details the projects' site accessibility information as required by California Title 24, Part 2 shall be submitted as part of the project Building Permit Plans. (Building)
16. For Multiple Building Complexes: As part of the required Architectural Site Accessibility Plan, the developer shall delineate the extent of the site accessibility improvements being installed as part of the initial improvements for the project, and those that are planned to be developed as part of subsequent phases (i.e. around future pad buildings). (Building)
17. Building permit plans shall comply with all applicable code requirements (California Building Code – CBC – based on the International Building Code, California Green Building Standards Code–CGBSC, California Mechanical Code – CMC – based on the Uniform Mechanical Code, California Plumbing Code – CPC – based on the Uniform Plumbing Code, California Fire Code – CFC – based on the International Fire Code – with City of Roseville Amendments – RFC, California Electrical Code – CEC – based on the National Electrical Code, and California Energy Standards – CEC T-24 Part 6), California Title 24 and the American with Disabilities Act - ADA requirements, and all State and Federally mandated requirements in effect at the time of submittal for building permits (contact the Building Division for applicable Code editions). (Building)
18. For restaurants, other food services, or commercial swimming pools: The developer shall obtain all required approvals and permits from the Placer County Health Department and the City of Roseville Industrial Waste Division. (Building, Environmental Utilities)
- 18-19. Maintenance of copy of building plans; Health and Safety Code Section 19850 requires the building department of every city or county to maintain an official copy of the building plans for the life

of the building. As such, each individual building shall be submitted as a separate submittal package. Building plan review, permit issuance, and archiving is based on each individual building address. (Building)

~~19-20.~~ For all work to be performed off-site, permission to enter and construct shall be obtained from the property owner, in the form of a notarized right of entry. Said notarized right of entry shall be provided to Engineering prior to approval of any plans. (Engineering)

~~20-21.~~ The Improvement Plans shall include a complete set of Landscape Plans. The Landscape Plans shall be approved with the Improvement Plans. (Planning, Engineering, Fire, Environmental Utilities, Electric)

~~21-22.~~ A note shall be added to the grading plans that states:

*“Prior to the commencement of grading operations, the contractor shall identify the site where the **excess/borrow** earthen material shall be imported/deposited. If the **borrow/deposit** site is within the City of Roseville, the contractor shall produce a report issued by a geotechnical engineer to verify that the exported materials are suitable for the intended fill, and shall show proof of all approved grading plans. Haul routes to be used shall be specified.”* (Engineering)

~~22-23.~~ The developer shall be responsible for the installation cost of a bus shelter and related improvements, conforming to the City's current standards for the shelter pad located on the southeast corner Blue Oaks Boulevard and Woodcreek Oaks Boulevard. The Developer shall enter into a construction fee agreement with the City and pay a construction cost of \$10,000 for future construction of the Bus Shelter (shelter number 283). (Public Works, Alternative Transportation)

~~23-24.~~ The developer shall include a 20-space park-and-ride lot per the Specific Plan requirements and in proximity to the intersection of Blue Oaks Boulevard and Woodcreek Oaks Boulevard. The park-and-ride lot shall include accessible parking as required by the building code, a path of travel from the accessible parking to the transit shelter on Blue Oaks Boulevard, signs identifying the park-and-ride spaces and their availability to the public. The landowner shall be responsible for maintenance of the park-and-ride lot and all its appurtenances. (Public Works, Alternative Transportation)

~~24-25.~~ The applicant shall dedicate all necessary rights-of-way or Public Utility Easement for the widening of any streets or transfer of public utilities across and over any portion of the property as required with this entitlement. A separate document shall be drafted for approval and acceptance by the City of Roseville, and recorded at the County Recorder's Office. (Public Works)

~~25-26.~~ Bike parking and clean air vehicle spaces shall be provided per the California Green Building Standards. Bike rack/locker design and location shall be approved by Alternative Transportation. Parking stall markings are to be marked as “Carpool/Clean Air/EV”. (Alternative Transportation, Building).

~~26-27.~~ All storm drainage, including roof drains, shall be collected on site and treated with Best Management Practices (BMP's) per the City's Stormwater Quality Design Manual. All storm water shall be routed to the nearest existing storm drain system or natural drainage facility. Drain outfalls shall extend down to the receiving water and shall be constructed with adequate velocity attenuation devices. The grading/improvement plans for the site shall be accompanied with a shed map that defines that area tributary to this site and all drainage facilities shall be designed to accommodate the tributary flow. The storm drain system and proposed BMP's shall be privately owned and maintained by the property owner. Prior to the issuance of any permits, the owner shall provide a plan for the maintenance of the proposed BMP's. (Engineering)

27-28. Prior to the approval of the Improvement Plans, the project proponent shall provide proof of preparation and submittal of a Storm Water Pollution Prevention Plan (SWPPP) to the Regional Water Quality Control Board (RWQCB). Proof shall be in the form of the Waste Discharge Identification Number (WDID#), provided to the applicant from RWQCB, placed on the coversheet of the improvement plans. Upon approval of the improvement plans, a copy of the SWPPP shall be required onsite and available for viewing by City inspection staff upon request. (Engineering)

28-29. The applicant shall remove and reconstruct any existing damaged curb, gutter, and sidewalk along the property frontage. During plan check of the improvement plans and/or during inspection, Engineering will designate the exact areas to be reconstructed. Any existing public facilities damaged during the course of construction shall be repaired by the property owner and at the property owner's expense, to the satisfaction of the City. (Engineering)

29-30. Prior to the approval of the Improvement Plans, it will be the project proponent's responsibility to pay the standard City Trench Cut Recovery Fee for any cuts within the City streets that are required for the installation of underground utilities. (Engineering)

30-31. Prior to issuance of Building Permits, the property owner shall pay into the following fee programs: Citywide Drainage Fee, Citywide Traffic Mitigation Fee (TMF), Highway 65 Joint Partners Association (JPA), South Placer Regional Transportation Authority (SPRTA), and City/County Fee. (Engineering)

31-32. Per the per the Development Agreement, the property owner shall pay their fair share on a City-wide basis of the Long Range Master Transit Plan, the Short Range Transit Plan, and the Bicycle Master Plan. (Alternative Transportation)

32-33. The applicant/developer shall participate in preparation of a Transportation Systems Management (TSM) Plan for the Campus Oaks Town Center to be reviewed and approved by the Transportation Commission. (Alternative Transportation)

33-34. Prior to issuance of a grading permit or approval of Improvement Plans, the grading plans shall clearly identify all existing water, sewer, and recycled water utilities within the boundaries of the project (including adjoining public right-of-way). Existing utilities shall be identified in plan-view and in profile-view where grading activities will modify existing site elevation over top of or within 15 feet of the utility. Any utilities that could potentially be impacted by the project shall be clearly identified along with the proposed protection measures. The developer shall be responsible for taking measures and incurring costs associated with protecting the existing water, sewer, and recycled water utilities to the satisfaction of the Environmental Utilities Director. (Environmental Utilities)

34-35. The applicant shall pay all applicable water and sewer fees. (Environmental Utilities)

35-36. Water and sewer infrastructure shall be designed pursuant to the adopted City of Roseville Improvement Standards and the City of Roseville Construction Standards and shall include:

- a) Utilities or permanent structures shall not be located within the area which would be disturbed by an open trench needed to expose sewer trunk mains deeper than 12 feet unless approved by Environmental Utilities in these conditions. The area needed to construct the trench is a sloped cone above the sewer main. The cone shall have 1:1 side slopes.
- b) Water, sewer, and recycled mains shall not exceed a depth of 12 feet below finished grade, unless authorized in these conditions of approval.

- c) All sewer manholes shall have all-weather, 10-ton vehicle access unless otherwise authorized by these conditions of approval. (Environmental Utilities)

36-37. Recycled water infrastructure shall be designed pursuant to the adopted City of Roseville Improvement Standards and City of Roseville Construction Standards. The applicants shall pay all applicable recycled water fees. Easements shall be provided as necessary for recycled water infrastructure. (Environmental Utilities)

37-38. Trash enclosures, recycling areas, and enclosure approaches shall be designed to current Refuse Division specifications, the materials and colors shall match the building, and the location of such facilities shall be reviewed and approved by the Refuse Division, Planning, and the Fire Department. The enclosure must have inside dimensions of 12 feet wide and 9 feet deep and be built to the specifications of the Solid Waste Department's Enclosure Description. (Refuse, Planning, Fire)

38-39. Access to trash enclosures shall have an inside turning radius of 25 feet and an outside turning radius of 45 feet must be maintained to allow the refuse truck access to and from the enclosure. Enclosures must have a clear approach of 65 feet in front of the enclosure to allow servicing bins. (Refuse)

39-40. A trash enclosure and recycling enclosure is required for each building and each tenant, otherwise, the building owner is responsible for the trash service. (Refuse)

40-41. The design and installation of all fire protection equipment shall conform to the California Fire Code and the amendments adopted by the City of Roseville, along with all standards and policies implemented by the Roseville Fire Department. (Fire)

41-42. The applicable codes and standards adopted by the City shall be enforced at the time construction plans have been submitted to the City for permitting. (Fire)

42-43. The Electric Department requires the submitted of the following information in order to complete the final electric design for the project:

- a) One (1) set of improvement plans
- b) Load calculations
- c) Electrical panel one-line drawings

43-44. All on-site external lighting shall be installed and directed to have no off-site glare. Lighting within the parking areas and pedestrian walkways shall provide a maintained minimum of one (1) foot candle, and a 0.5 foot-candle of light, respectively. All exterior light fixtures shall be vandal resistant. (Planning, Police)

44-45. The parking lot shall have properly posted signs that state the use of the parking area is for the exclusive use of employees and customers of this project. (See California Vehicle Code Sections 22507.8, 22511.5, 22511.8, 22658(a), and the City of Roseville Municipal Code Section 11.20.110). The location of the signs shall be shown on the approved site plan. (Planning, Police)

45-46. It is the developer's responsibility to notify PG&E of any work requiring on PG&E facilities. (PG&E)

**DURING CONSTRUCTION & PRIOR TO ISSUANCE OF OCCUPANCY PERMITS:**

46-47. Any backflow preventers visible from the street shall be painted to blend in with the surrounding landscaping. The backflow preventers shall be screened with landscaping and shall comply with the following criteria:

- a) There shall be a minimum clearance of four feet (4') on all sides, from the backflow preventer to the landscaping.
- b) For maintenance purposes, the landscaping shall only be installed on three sides and the plant material shall not have thorns.
- c) The control valves and the water meter shall be physically unobstructed.
- d) The backflow preventer shall be covered with a green cover that will provide insulation (Planning, Environmental Utilities)

47-48. Easement widths shall comply with the City's Improvement Standards and Construction Standards. Separate document easements required by the City shall be prepared in accordance with the City's "Policy for Dedication of Easements to the City of Roseville". All legal descriptions shall be prepared by a licensed land Surveyor. All existing public utility, electric, water, sewer, and reclaimed water easements shall be maintained unless otherwise authorized by these conditions of approval. (Engineering, Environmental Utilities, Electric)

48-49. Inspection of the potable water supply system on new commercial/industrial/office project shall be as follows:

- a) The Environmental Utilities Inspector will inspect all potable water supply up to the downstream side of the backflow preventer.
- b) The property owner/applicant shall be responsible for that portion of the water supply system from the backflow preventer to the building. The building/contractor shall engage a qualified inspector to approve the installation of this portion of the water supply. The Building Division will require from the builder/contractor, a written document certifying that this portion of the potable water supply has been installed per improvement plans and in accordance with the Uniform Plumbing Code. This certificate of compliance shall be submitted to the Building Division before a temporary occupancy or a building final is approved.
- c) The building inspectors will exclusively inspect all potable water supply systems for the building from the shutoff valve at the building and downstream within the building. (Building, Environmental Utilities)

49-50. All improvements being constructed in accordance with the approved grading and improvement plans shall be accepted as complete by the City. (Engineering)

50-51. The words "traffic control appurtenances" shall be included in the list of utilities allowed in public utilities easements (PUE's) located along public roadways. (Engineering)

51-52. Water, sewer, and reclaimed water shall be constructed pursuant to the adopted City of Roseville Improvement Standards and the City of Roseville Construction Standards. (Environmental Utilities)

52-53. All water backflow devices shall be tested and approved by the Environmental Utilities Department. (Environmental Utilities)

53-54. Restaurants or other Food Service Establishment (FSE). The applicant shall design for installation and/or install an exterior grease interceptor if the proposed business could potentially discharge substances containing fats, oils, and grease (FOG) into the sewer system. The grease interceptor shall be adequate to separate and remove FOG contained in the wastewater from FSE's prior to discharge to the public sewer. (Environmental Utilities)

54-55. In the event an exterior grease interceptor cannot be installed due to space limitation, the developer shall install a grease trap, per City Standards, that will mechanically separate the FOG contained in the wastewater from the FSE prior to discharge to the public sewer. (Environmental Utilities)

55-56. Pursuant to the Municipal Code, the applicant shall apply for and obtain a FOG waste discharge permit (FOG WDP) from the Environmental Utilities Industrial Waste Division prior to occupancy or prior to discharging waste to the public sewer. The applicant shall submit information required by the Environmental Utilities Department for reevaluation, including but not limited to site plans, floor plans, mechanical and plumbing plans, and details to show all sewers, FOG control device, grease interceptor or other pretreatment equipment and appurtenances by size, location and elevation. Additional information related to the applicant's business operations and potential discharge may be requested to properly evaluate the FOG WDP application. (Environmental Utilities)

56-57. All Electric Department facilities, including streetlights where applicable, shall be designed and built to the "City of Roseville Specifications for Commercial Construction." (Electric)

57-58. The City of Roseville Electric Department has electrical construction charges which are to be paid by the developer and which are explained in the City of Roseville "Specification for Commercial Construction." These charges will be determined upon completion of the final electrical design. (Electric)

58-59. Any relocation, rearrangement, or change of existing electric facilities due to this development shall be at the developer's expense. (Electric)

59-60. Any facilities proposed for placement within public/electric utility easements shall be subject to review and approval by the Electric Department before any work commences in these areas. This includes, but is not limited to, landscaping, lighting, paving, signs, trees, walls, and structures of any type. (Electric)

60-61. All electric metering shall be directly outside accessible. This can be accomplished in any of the following ways:

- a) Locate the metered service panel on the outside of the building.
- b) Locate the metered service panel in a service room with a door that opens directly to the outside. The developer will be required to provide a key to the door for placement in a lock box to be installed on the outside of the door. Any doors leading from the service room to other areas of the building shall be secured to prohibit unauthorized entry. (Electric)

61-62. One 3/4 inch conduit with a 2-pair phone line shall be installed from the building's telephone service panel to the meter section of the customer's electrical switchgear or panel. (Electric)

~~62-63.~~ It is the responsibility of the developer to ensure that all existing electric facilities remain free and clear of any obstruction during construction and when the project is complete. (Electric)

**OTHER CONDITIONS OF APPROVAL:**

~~63-64.~~ Signs shown on the elevations are not approved as part of the Major Project Permit. A Sign Permit is required for all project signs. (Planning)

~~64-65.~~ Following the installation of the landscaping, all-landscaping material shall be maintained in a healthy and weed-free condition; dead plant material shall be replaced immediately. All trees shall be maintained and pruned in accordance with the accepted practices of the International Society of Arboriculture (ISA). (Planning)

~~65-66.~~ The City reserves the right to restrict vehicle turning movements within the public right-of-way in the future if deemed necessary by the City Engineer. (Engineering)

~~66-67.~~ The required width of fire apparatus access roads shall not be obstructed in any manner, including the parking of vehicles. Minimum required widths and vertical clearances established by the Fire Code shall be maintained at all times during construction. Closure of accesses for fire apparatus by gates, barricades, and other devices shall be prohibited unless approved by the Fire Chief. (Fire)

~~67-68.~~ Temporary aboveground storage tanks may be used at construction sites for diesel fuel only and shall not exceed 1,000-gallon capacity. Tanks shall comply with all provisions found within the Fire Code. A Fire Department Permit shall be obtained prior to tank installation. The permit shall expire after 90 days from the date of issuance, unless extended by the Fire Chief. (Fire)

~~68-69.~~ If site survey or earth moving work results in the discovery of hazardous materials in containers or what appears to be hazardous wastes released into the ground, the contractor or person responsible for the building permit must notify the Roseville Fire Department immediately. A representative from the Fire Department will make a determination as to whether the incident is reportable or not and if site remediation is required. (Fire)

~~69-70.~~ The location and design of the gas service shall be determined by PG&E. The design of the gas service for this project shall not begin until PG&E has received a full set of City approved improvement plans for the project. (PG&E)

~~70-71.~~ All commercial air conditioning units 5 tons or less (<65,000 btu/ h) shall meet the current Consortium for Energy Efficiency ("CEE") Tier I specifications. The SEER/EER ratings will be specified on building plans and Title 24 compliance certificates at the time building permits are requested. The SEER and EER ratings will be verified with appropriate documentation. These requirements shall be utilized in the overall energy compliance calculations required for issuance of any building permit for any commercial building in the Plan Area. Any variances, with the exception of Tier 2 compliance, must be approved by the Electric Department's Retail Energy Services Department. (Electric)

~~71-72.~~ The project is subject to the noise standards established in the City's Noise Ordinance. In accordance with the City's Noise Ordinance, project construction is exempt between the hours of seven a.m. and seven p.m. Monday through Friday, and between the hours of eight a.m. and eight p.m. Saturday and Sunday, provided that all construction equipment shall be fitted with factory installed muffling devices and be maintained in good working order. (Building)

72.73. The developer (or designated consultant) shall certify that the building foundation location has been placed according to all approved setback requirements shown on the approved site plan. The developer shall prepare a written statement confirming building placement and provide an original copy to the City Building Division Field Inspector at the time of or prior to the foundation inspection. (Building)

73.74. Prior to Certificate of Occupancy, the applicant may apply for a Temporary Certificate of Occupancy (TCO) of the building. If a TCO is desired, the applicant must submit a written request to the Building Division a minimum of thirty (30) days prior to the expected temporary occupancy date and shall include a schedule for occupancy and a description of the purpose for the Temporary Certificate of Occupancy. (Building)

74.75. Concurrent with submittal for plan check and prior to a request for final building inspection, the applicant may request City approval of an occupancy phasing plan to allow individual or multiple building occupancies. This request shall be made in writing to the Building Division and shall include the following:

- a) A description of measures that will be undertaken to minimize conflict between residents/building occupants and construction traffic (e.g. fencing, etc.);
- b) A phasing plan showing the proposed buildings, internal roads and access routes, landscaping, trash enclosure locations, and any other improvements planned for each phase; and
- c) An estimated time frame for each phase and a specific date for the first phase. (Planning, Building)

## **Exhibits**

### **A. Plans**

<p><b>Note to Applicant and/or Developer:</b> Please contact the Planning Division staff at (916) 774-5276 prior to the Commission meeting if you have any questions on any of the recommended conditions for your project. If you challenge the decision of the Commission in court, you may be limited to raising only those issues which you or someone else raised at the public hearing held for this project, or in written correspondence delivered to the Planning Manager at, or prior to, the public hearing.</p>
---