



Development Services Department
Building Division
311 Vernon Street
Roseville, California 95678-2649
(916) 774-5332 • Fax (916) 774-5394

Electric Load Worksheet

Address: _____ Date: _____

Main Electric Panel Service Size: Existing _____ (Amps) / New (if applicable) _____ (Amps)

Quantity of Existing Subpanels: _____ Quantity of New Subpanels: _____ Gas Furnace (Y/N) _____

Breaker Size(s) feeding subpanel(s)? _____ Wires Size(s) feeding subpanel(s)? _____

A. Calculate Habitable¹ Square Footage

_____ (Existing S.F.) + _____ (New S.F., if any) = _____ Total Habitable Square Footage

B. Identify General Loads

General Lighting and Use Receptacles:	_____	Total Habitable Sq. Ft. x 3	= _____	total watts
Kitchen Small Appliance Branch Circuits:	_____	(Quantity, Min. 2) x 1500	= _____	total watts
Bathroom Small Appliance Branch Circuits:	_____	(Quantity, Min. 1) x 1500	= _____	total watts
Range:	_____	(Nameplate Rating) x 1	= _____	total watts
Oven:	_____	(Nameplate Rating) x 1	= _____	total watts
Water Heater:	_____	(Nameplate Rating) x 1	= _____	total watts
Dishwasher:	_____	(Nameplate Rating) x 1	= _____	total watts
Garbage Disposal:	_____	(Nameplate Rating) x 1	= _____	total watts
Washer:	_____	(Nameplate Rating) x 1	= _____	total watts
Dryer*:	_____	(Nameplate Rating*) x 1	= _____	total watts*
Total Subpanel Load ² :	_____	(Amperage Rating) x 240	= _____	total watts
Motor Loads:	_____	(Nameplate Rating) x 1	= _____	total watts
Other Loads**:	_____	(Nameplate Rating**) x 1	= _____	total watts**

*For Electric Dryer use 5,000 watts minimum, CEC 220.54

**For EVSE use 7200 watts minimum, CEC 220.57

Add total watts together (from above) = _____ Total B

C. Identify Largest of the Following Six Heating and Air Conditioning (HAC) Loads

Electric Thermal Storage:	_____	(Nameplate Rating) x 1	= _____	total watts
Air Conditioning and Cooling:	_____	(Nameplate Rating) x 1	= _____	total watts
Heat Pump (without any supplemental electric heating):	_____	(Nameplate Rating) x 1	= _____	total watts
3 or Less ³ Electric Space Heating Units:	_____	(Nameplate Rating) x 0.65	= _____	total watts
4 or more ³ Electric Space Heating Units:	_____	(Nameplate Rating) x 0.40	= _____	total watts
Central Electric Space Heating System ⁴ :	_____	(Combined Nameplate Rating ⁴)	= _____	total watts

Enter single largest Heating and Air Conditioning Load (from above) = _____ Total C

D. Calculate Total Service Load

_____ - 10,000 watts x 0.40 + 10,000 watts + _____ ÷ 240 = _____ Total Amps
Total B (from above) Total C (from above)

Signature _____

Print Name _____

State License Number (if applicable) _____

¹Habitable square footage includes the floor area for each floor, calculated from the outside dimensions of the dwelling unit. It does not include open porches, garages, or unused or unfinished spaces not adaptable for future use as a habitable room or occupiable space.

²Add all subpanel loads here, that serve the specific dwelling unit to be calculated, that are not already included elsewhere on this form.

³Separately controlled.

⁴For Central Electric Space Heating Systems, add 100% of the heat pump compressor's nameplate rating plus 65% of the supplemental electric heating's nameplate rating. If the heat pump compressor is prevented from operating at the same time as the supplementary heat, it does not need to be added to the supplementary heat for the total central space heating load.